



Product Service

Compliance Document

No. D 073342 0285 Rev. 00

Holder of Certificate: **Sungrow Power Supply Co., Ltd.**

No. 1699 Xiyou Road, New & High
Technology Industrial Development Zone,
230088 Hefei, Anhui
PEOPLE'S REPUBLIC OF CHINA

Product:

Converter
Grid-Connected PV Inverter

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. See also notes overleaf.

Test report no.: 704091903331-00

Date, 2019-12-06


(Zhengdong Ma)

TUV SUD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

Compliance Document

No. D 073342 0285 Rev. 00

Model(s): SG110CX

Parameters:

Max. Input Voltage:	DC 1100 V
Min. MPP Voltage:	DC 200 V
Max. MPP Voltage:	DC 1000 V
Max. Input Current:	DC 9*26 A
Isc PV:	DC 9*40 A
Rated Output Voltage:	3/N/PE~, 400/230V
Rated Output Frequency:	50 Hz
Max. Output Current:	AC 158,8 A
Rated Output Power:	100 kW
Max. Apparent Power:	110 kVA
Power factor range:	0,8 Leading...0,8 Lagging
Protective Class:	I
Overvoltage Category:	III[AC], II[DC]
Ingress Protection:	IP66
Ambient Temperature:	-30 °C...+60 °C
Inverter topology	Non-isolated

Tested according to: EN 50549-2:2019/AC:2019

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

A4 / 07.17